



October 18, 2024

Addendum No. 2

BL114-24 M-1357-01 F-1546-01 & M-1238-28 Lakeview Rd at Pharrs Rd-Hillside Dr

THE FOLLOWING CHANGES WERE MADE TO THE BID SCHEDULE:

1. Page 3 of 7, Item 210 500-3002 CLASS AA CONCRETE, CY 34 was CHANGED to Item 210 500-3002 CLASS AA CONCRETE, CY 40.
2. Page 3 of 7, Item 220 511-1000 BAR REINF STEEL, LB 3,350 was CHANGED to Item 220 511-1000 BAR REINF STEEL, LB 3,900.

FOR THE CONTRACTORS' INFORMATION:

- Q1.** The special grading drawing does not show the existing contour lines in the portion where the new roundabout is proposed. Please provide existing contour lines on the entire area of the special grading plan.
- A1.** Contractor to use the plan cross sections along with the special grading plan to obtain the information for the area at the roundabout.
- Q2.** Is the contractor responsible for onsite material testing?
- A2.** No.
- Q3.** Can you provide a utility relocation schedule, showing the anticipated dates that utility companies will be completed with the relocation of their facilities?
- A3.** No.
- Q4.** Will water monitoring and monthly inspections be required for the project? If so, please add the item.
- A4.** No.
- Q5.** Is video inspection for drainage pipe required on this project?
- A5.** Video Inspection of drainage pipe will be required in accordance with **GDOT Specification.**
- Q6.** Why is the item salvage fire hydrant two times in the schedule of values?
- A6.** The DWR item were separated out, bidder to bid both items.

Q7. Why is the item Fire Hydrant two times in the schedule of values?

A7. The DWR item were separated out, bidder to bid both items.

Q8. Why is the item service line two times in the schedule of values?

A8. The DWR item were separated out, bidder to bid both items.

Q9. When do you anticipate construction to start?

A9. First Quarter of 2025

Q10. What pattern needs to be used for the stamped colored red pavement?

A10. See **GDOT Construction Detail RA-2 for information.**

Q11. Please provide the dowel bar size and spacing for the plain concrete pavement class 3.

A11. See **GDOT Construction Detail RA-2 for information.**

Q12. It is our understanding that item 210 "Class AA concrete" 34 CY is intended for the box culvert extension and the wing walls. Per GDOT standard detail 2401 2-M, the new 18 LF of the box culvert, including the parapet and toe wall, will require 33.11 CY. Additionally, per GDOT 2404 the wingwalls will require 12.4 CY of concrete. The total for this line item should be 46 CY. Please revise item quantities if our reasoning is correct.

A12. Per **GDOT Standard 2404 note, the quantities for wingwall, wingwall footing, etc. are for both ends. This project is only extending the outlet end; therefore, the quantities would be half. Bid quantities have been adjusted to account for wingwall quantities.**

ATTACHMENTS:

- Revised Bid Schedule (Pages 1-7)

RECEIPT OF BIDS REMAINS 2:50 PM LOCAL TIME, THURSDAY, OCTOBER 24, 2024

All bidders shall acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject the bidder to disqualification. This addendum forms a part of the Contract Documents.

You should acknowledge receipt on Page I-4 of the bidding documents.

Thank you,

Purchasing Associate II

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
005	009-3100	AERIAL PHOTOGRAPH DOCUMENTATION	MO	10		
010	150-1000A	TRAFFIC CONTROL - PROJECT NO. M-1357-01	LS	1		
015	150-1000B	TRAFFIC CONTROL - PROJECT NO. F-1546-01	LS	1		
020	161-1000A	EROSION CONTROL, PROJECT NO. M-1357-01	LS	1		
025	161-1000B	EROSION CONTROL, PROJECT NO. F-1546-01	LS	1		
030	163-0538	CONSTRUCT, MAINTAIN AND REMOVE CHECK DAM	EA	29		
035	163-0551	CONSTRUCT, MAINTAIN AND REMOVE INLET SEDIMENT TRAP	EA	22		
040	171-0030	TEMPORARY SILT FENCE, TYPE C	LF	4,427		
045	207-0203	FOUND BK FILL MATL, TP II	CY	200		
050	210-0100A	GRADING COMPLETE - PROJECT NO. M-1357-01	LS	1		
055	210-0100B	GRADING COMPLETE - PROJECT NO. F-1546-01	LS	1		
060	210-0250A	UNDERCUT EXCAVATION - PROJECT NO. M-1357-01 (PER SPECIFICATION 210.5C)	CY	750	\$18.00	\$13,500.00
065	210-0250B	UNDERCUT EXCAVATION - PROJECT NO. F-1546-01 (PER SPECIFICATION 210.5C)	CY	750	\$18.00	\$13,500.00
070	310-1101	GR AGGR BASE CRS, INCL MATL	TN	2,062		
075	318-3000	AGGR SURF CRS	TN	200		

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
080	402-1802	RECYCLED ASPH CONC PATCHING, INCL BITUM MATL & H LIME	TN	50		
085	402-1812	RECYCLED ASPH CONC LEVELING, INCL BITUM MATL & H LIME	TN	322		
090	402-3121	RECYCLED ASPH CONC 25 MM SUPERPAVE, GP 1 OR 2, INCL BITUM MATL & H LIME	TN	501		
095	402-3130	RECYCLED ASPH CONC 12.5 MM SUPERPAVE, GP 2 ONLY, INCL BITUM MATL & H LIME	TN	447		
100	402-3190	RECYCLED ASPH CONC 19 MM SUPERPAVE, GP 1 OR 2, INCL BITUM MATL & H LIME	TN	261		
105	413-0750	TACK COAT	GL	513		
110	432-5010	MILL ASPH CONC PVMT, VARIABLE DEPTH	SY	663		
115	439-0022	PLAIN PC CONC PVMT, CL 3 CONC, 10 INCH THK	SY	339		
120	441-0016	DRIVEWAY CONCRETE, 6 IN TK	SY	545		
125	441-0104	CONC SIDEWALK, 4 IN	SY	1,919		
130	441-0108	CONCRETE SIDEWALK, 8 IN	SY	265		
135	441-0754	CONCRETE MEDIAN, 7 1/2 IN	SY	127		
140	441-4020	CONC VALLEY GUTTER, 6 IN	SY	378		
145	441-5008	CONCRETE HEADER CURB, 6 IN, TP 7	LF	217		
150	441-5025	CONCRETE HEADER CURB, 4 IN, TP 9	LF	295		

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
155	441-6222	CONC CURB & GUTTER, 8 IN X 30 IN, TP 2	LF	3,793		
160	444-1000	SAWED JOINTS IN EXISTING PAVEMENTS, PCC	LF	234		
165	446-1100	PVMT REINF FABRIC STRIPS, TP 2, 18 INCH WIDE	LF	607		
170	500-9999	CLASS B CONCRETE, BASE OR PVMT WIDENING	CY	90		
175	641-1200	GUARDRAIL, TYPE W	LF	205		
180	641-5001	GUARDRAIL ANCHORAGE, TP 1	EA	2		
185	641-5015	GUARDRAIL TERMINAL, TP 12A, 31 IN, TANGENT, ENERGY-ABSORBING	EA	2		
190	643-8200	BARRIER FENCE (ORANGE), 4 FT	LF	150		
195	700-0200A	GRASSING COMPLETE (SOD) - PROJECT NO. M-1357-01	LS	1		
200	700-0200B	GRASSING COMPLETE (SOD) - PROJECT NO. F-1546-01	LS	1		
205	711-0100	TURF REINFORCING MATTING, TP 1	SY	215		
DRAINAGE						
210	500-3002	CLASS AA CONCRETE	CY	40		
215	500-3800	CLASS A CONCRETE, INCL REINF STEEL	CY	4		
220	511-1000	BAR REINF STEEL	LB	3,900		
225	550-3624	SAFETY END SECTION 24 IN, SIDE DRAIN, 6:1 SLOPE	EA	1		

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
230	550-4224	FLARED END SECTION, 24 IN, STORM DRAIN	EA	1		
235	550-4230	FLARED END SECTION, 30 IN, STORM DRAIN	EA	1		
240	550-5180	STORM DRAIN PIPE, 18 IN, CLASS III	LF	2,017		
245	550-5240	STORM DRAIN PIPE, 24 IN, CLASS III	LF	313		
250	550-5300	STORM DRAIN PIPE, 30 IN, CLASS III	LF	60		
255	573-2006	UNDDR PIPE INCL DRAINAGE AGGR, 6 IN	LF	200		
260	600-0001	FLOWABLE FILL	CY	10		
265	603-2024	STN DUMPED RIP RAP, TP 1, 24 IN	SY	14		
270	603-2181	STN DUMPED RIP RAP, TP 3, 18 IN	SY	34		
275	603-7000	PLASTIC FILTER FABRIC	SY	48		
280	611-3030	RECONSTR STORM SEW MANHOLE, TYPE 1	EA	1		
285	668-1100	CATCH BASIN, GP 1	EA	13		
290	668-1110	CATCH BASIN, GP 1, ADDL DEPTH	LF	7		
295	668-2100	DROP INLET, GP 1	EA	10		
300	668-2110	DROP-INLET, GP 1 ADDL DEPTH	LF	3		

SIGNING AND MARKING

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
305	632-0003	CHANGEABLE MESSAGE SIGN, PORTABLE, TYPE 3		3		
310	636-1033	HIGHWAY SIGNS, TP 1 MATL, REFL SHEETING, TP 9	SF	91		
315	636-1036	HIGHWAY SIGNS, TP 1 MATL, REFL SHEETING, TP 11	SF	156		
320	636-2070	GALV STEEL POSTS, TP 7	LF	346		
325	636-2080	GALV STEEL POSTS, TP 8	LF	47		
330	636-2090	GALV STEEL POSTS, TP 9	LF	90		
335	636-3010	GROUND-MOUNTED BREAKAWAY SIGN SUPPORT	EA	3		
340	636-5025	HP FLEX POST DELINEATOR, TP 2B, 42 IN WHITE	EA	6		
345	653-0296	THERMOPLASTIC PVMT MARKING, WORD, TP 15	EA	3		
350	653-6006	THERMOPLASTIC TRAF STRIPING, YELLOW	SY	118		
355	653-1704	THERMOPLASTIC SOLID TRAF STRIPE, 24 IN, WHITE	LF	18		
360	653-1804	THERMOPLASTIC SOLID TRAF STRIPE, 8 IN, WHITE	LF	724		
365	653-4830	THERMOPLASTIC SKIP TRAF STRIPE, 18 IN, WHITE	GLF	84		
370	653-8026	WET WEATHER THERMOPLASTIC SOLID TRAFFIC STRIPE, 5 IN, WHITE	LF	1,759		
375	653-8031	WET WEATHER THERMOPLASTIC SOLID TRAFFIC STRIPE, 5 IN, YELLOW	LF	1,104		

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
380	654-1001	RAISED PVMT MARKERS TP 1, 2, 3	EA	22		

UTILITY

385	331219.81-AVB	ADJUST VALVE BOX	EA	5		
-----	---------------	------------------	----	---	--	--

390	331213-1LS	WATER SERVICE CONNECTIONS – ¾ IN - 1 IN LONG SIDE SERVICE CONNECTIONS	EA	2		
-----	------------	---	----	---	--	--

395	331213-1SS	WATER SERVICE CONNECTIONS – ¾ IN - 1 IN SHORT SIDE SERVICE CONNECTIONS	EA	8		
-----	------------	--	----	---	--	--

400	330516.13-ATP	ADJUST MANHOLE FRAME AND COVERS TO GRADE - 1 VERTICAL FT. OR LESS, PAVEMENT	EA	3		
-----	---------------	---	----	---	--	--

405	331219	FIRE HYDRANT	EA	2		
-----	--------	--------------	----	---	--	--

410	331213-SFH	SALVAGE EXISTING FIRE HYDRANTS	EA	2		
-----	------------	--------------------------------	----	---	--	--

GCDWR WATER MAIN

415	330523.16-240	STEEL CASING, OPEN CUT INSTALLATION - 24 IN DIAMETER	LF	120		
-----	---------------	--	----	-----	--	--

420	331213-1LS	WATER SERVICE CONNECTIONS - ¾ IN – 1 IN LONG SIDE SERVICE CONNECTION	EA	6		
-----	------------	--	----	---	--	--

425	331213-1ELS	¾ IN – 1 IN EXTRA LONG SERVICE LINE INSTALLATION > 5 LANES	EA	1		
-----	-------------	--	----	---	--	--

430	331216-8GV	GATE VALVES - 8 IN	EA	1		
-----	------------	--------------------	----	---	--	--

435	331216-10GV	GATE VALVES - 10 IN	EA	1		
-----	-------------	---------------------	----	---	--	--

440	331216-12GV	GATE VALVES - 12 IN	EA	2		
-----	-------------	---------------------	----	---	--	--

445	331113.05-8D	DUCTILE IRON PIPE - 8 IN DIAMETER	LF	17		
-----	--------------	-----------------------------------	----	----	--	--

450	331113.05-12D	DUCTILE IRON PIPE - 12 IN DIAMETER	LF	2,720		
-----	---------------	------------------------------------	----	-------	--	--

COMPANY NAME: _____
Failure to return this page my result in rejection of bid.

GWINNETT COUNTY, GEORGIA	
PROJECT #:	M-1357-01, F-1546-01 & M-1238-28
PROJECT:	Lakeview Road at Pharrs Road / Hillside Drive
BID NUMBER:	BL114-24

ADDENDUM NO. 2
(REVISED BID SCHEDULE)

BID SCHEDULE

Item #	GDOT #	Description	Units	Est. Bid Quantity	Unit Price Bid	Total Price Bid
455	331213-SFH	SALVAGE EXISTING FIRE HYDRANTS	EA	3		
460	331219	FIRE HYDRANT	EA	5		
465	033000-A	CAST-IN-PLACE CONCRETE - CLASS A	CY	5		
470	331216-12X10	TAPPING SLEEVES AND VALVES - 12 IN x 10 IN	EA	2		
475	330516	PROJECT RECORD DOCUMENTS (DWR)	LS	1		
TOTAL						

CERTIFICATION OF NONCOLLUSION IN BID PREPARATION _____
(Signature) (Date)

The County requires that all who enter into a contract for the physical performance of services with the County must satisfy O.C.G.A. § 13-10-91 and Rule 300-10-1-.02, in a manner, and such are conditions of the contract.

In compliance with the attached specifications, the undersigned offers and agrees, if this bid is accepted by the Board of Commissioners within one hundred twenty (120) days of the date of bid opening, to furnish any or all of the items upon which prices are quoted within the time specified in the bid schedule. By submission of this bid, I understand that Gwinnett County uses Electronic Payments for remittance of goods and services. Vendors should select their preferred method of electronic payment upon notice of award. For more information on electronic payments, please refer to the Electronic Payment information in the Instructions to Bidders.

LEGAL BUSINESS NAME: _____
(If your company is an LLC, you must identify all principals to include address and phone numbers in your submittal)

ADDRESS: _____

DOES YOUR COMPANY CURRENTLY HAVE A LOCATION WITHIN GWINNETT COUNTY? YES NO

REPRESENTATIVE SIGNATURE: _____

PRINT AUTHORIZED REPRESENTATIVE'S NAME: _____

TELEPHONE NUMBER: _____ FAX: _____

E-MAIL ADDRESS _____

COMPANY NAME: _____
 Failure to return this page my result in rejection of bid.