



**November 18, 2024**

**Addendum No. 1**

**BL142-24**

**M-1068-01**

**Sugarloaf Parkway at SR 8 / US 29 / Lawrenceville Hwy**

**FOR THE CONTRACTORS' INFORMATION:**

- Q1.** Is builders risk insurance required for this project?
- A1.** **Builder risk insurance is not required for this project.**
- Q2.** Does the 105 available days allowed for construction include any utility relocation time? This is short timeline to complete the proposed scope in addition to any utility relocations that will be necessary. Can Gwinnett consider extending the completion to be at least 180 calendar days?
- A2.** **Time will not be changed.**
- Q3.** Aerial Photograph pay item currently has a quantity of 7 MO, however, the current completion date is less than that. Is there a reason for 7 months?
- A3.** **7 months is to cover time based on available days as stated in Q2,**
- Q4.** The GA DOT Notes on dwg 04-0002 have different required pavement specs than what is shown in the typical sections. Please clarify which one is correct.
- A4.** **The general note on 4-0002 would apply to any full depth asphalt paving on SR 8/US 29. However, the minor sections on SR 8/US 29 where full depth paving is required falls under the criterial of Class B Concrete widening. In summary, the typical sections should be followed for pavement specs.**
- Q5.** How soon is the County expecting to award this project?
- A5.** **1<sup>st</sup> quarter of 2025.**
- Q6.** The proposed new signal poles look to be in the same footprint as the existing signal poles. Can the existing signal poles be used, and only new signal heads added?
- A6.** **No.**
- Q7.** The plans show 10" solid and 10" skip being used for the bike lanes but there is no pay item. How will this be paid?
- A7.** **The bike lane striping should be 5 in solid and skip.**

**RECEIPT OF BIDS REMAINS 2:50 PM LOCAL TIME, THURSDAY, NOVEMBER 21, 2024**

All bidders shall acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject the bidder to disqualification. This addendum forms a part of the Contract Documents.

You should acknowledge receipt on Page I-4 of the bidding documents.

Thank you,

Michael Milstein  
Purchasing Associate II