



December 18, 2024

**ADDENDUM #1  
BL005-25  
Purchase of a Sodium Hypochlorite Tank**

**I. Questions:**

**Q1. Are there any bonds required to submit a bid?**

A1. No, bonds are not required.

**Q2. What is the specification of the tank size?**

A2. Tank size specifications are listed under Paragraph 2.7.A of section 43 4145 – Fiberglass Reinforced Plastic Tanks:  
Capacity: 22,000 gallons  
Diameter: 12 ft  
Height: 27.5 ft (or as required to meet the capacity)

This addendum should be signed in the space provided below and returned with your quote. Failure to do so may result in your quote being deemed non-responsive.

Thank you,

Brittany Bryant, CPPB  
Purchasing Associate III

Company Name \_\_\_\_\_

Authorized Representative \_\_\_\_\_